



HMC399



MCB 3P 15kA C-125A 4.5M

Technical properties

Number of protected poles	3
Number of poles	3 F
Curve	(
Functions	
Concurrently switching N-neutral	No
Configuration	
Number of modules	4
Connectivity	
Top connection alignement for modular devices	Aligned termina
Bottom connection alignement for modular devices	Aligned termina
Main electrical features	
Rated short circuit breaking capacity Icn AC according IEC60898-1	15 k
Rated operational voltage Ue	415
Type of supply voltage	A
Frequency	50/60 H
Voltage	
Rated insulation voltage	500
Rated impulse withstand voltage	6000
Electric current	
Rated current	125
Rated service breaking capacity Ics AC according IEC 60898-1	7.5 k
min/maxi threshold value of the AC thermal operation	1.13 / 1.45
Magnetic regulating currrent	5 / 10
Rating current 40°C according to IEC 60947	125
Rating current 45°C according to IEC 60947	122
Rating current 50°C according to IEC 60947	119
Rating current 55°C according to IEC 60947	115.7
Rating current 60°C according to IEC 60947	112
Rating current 65°C according to IEC 60947	109.1

	4.5
Breaking capacity on 1 pole for IT 415V NF 60947-2	4.5
Rated short circuit breaking capacity Icn under 230V AC according IEC60898-1	15
Rated short circuit breaking capacity Icn under 400V AC according IEC60898-1	15
Rated service breaking capacity Ics AC according IEC 60947-2	5
Rated ultimate short-circuit breaking capacity Icu under 230V AC IEC 60947-2	15
Rated ultimate short-circuit breaking capacity Icu under 240V AC IEC 60947-2	15
Rated ultimate short-circuit breaking capacity Icu under 400V AC IEC 60947-2	15
Rated ultimate short-circuit breaking capacity Icu under 415V AC IEC 60947-2	15
Electric current / temperature	
Rating current 30°C	12
Rating current 35°C	12
Rating current 40°C	11
Rating current 45°C	115.
Rating current 50°C	11
Rating current 55°C	109.
Rating current 60°C	105.
Current correction factors	
Correction factor of rating current for 2 devices placed side-by-side	
Correction factor of rating current for 3 devices placed side-by-side	0
Correction factor of rating current for 4 and	
5 devices placed side-by-side	
	0
5 devices placed side-by-side Correction factor of rating current for 6	0
5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Dimensions	
5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Dimensions Depth of installed product	70
5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Dimensions Depth of installed product	70 90
5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Dimensions Depth of installed product Height of installed product	70 90
5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Dimensions Depth of installed product Height of installed product Width of installed product	70 i 90 i 80 i
5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Dimensions Depth of installed product Height of installed product Width of installed product Frequency	70 i 90 i 80 i
5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Dimensions Depth of installed product Height of installed product Width of installed product Frequency Frequency Power	70 90 80 50 to 60
5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Dimensions Depth of installed product Height of installed product Width of installed product Frequency Frequency	70 r 90 r 80 r 50 to 60 34.93
5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Dimensions Depth of installed product Height of installed product Width of installed product Frequency Frequency Power Total power loss under IN	70 r 90 r 80 r 50 to 60 34.93
5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Dimensions Depth of installed product Height of installed product Width of installed product Frequency Frequency Power Total power loss under IN Power loss per pole at In	0 70 r 90 r 80 r 50 to 60 34.93 12

Installation, mounting

Type of top connection for modular devices	with screw
Tightening torque	3,5 to 5Nm
Type of top rail clip for modular devices	Plastic
Type of bottom rail clip for modular devices	plastic
Type of Bottom Connection for modular devices	with screw
Top removability for modular devices	Yes
Bottom removability for modular devices	Yes
Connection	
Connection cross-section at output with screw, for flexible conductor	1 / 50 mm²
Connection cross-section at output with screw, for massive conductor	1 / 70 mm²
Connection cross-section for rigid conductor, upstream terminals with screws	1 / 70 mm²
Connection cross-section of the access with screws, with flexible conductor	1 / 50 mm²
Connection cross-section of input and output with screws, for massive conductors	1 / 70 mm²
Connection cross section of access and exit with screws, for flexible conductor	1 / 50 mm²
Type of connection	terminal with tightening compensation system
Standards	
Standard text	EN 60898-1 ; IEC 60947-2
Safety	
Protection index IP	IP20
REACH conform	Yes
RoHS conform	Yes
Halogen free	No
Use conditions	
Degree of pollution according to IEC 60664 / IEC 60947-2	3
Altitude	2000 m
Air humidity protection	for all climates

temperatur

Temperature of calibration

30 °C